# **307CO**



Seismic Cabinet Model BTDA - Kit Bellcore 4

# **307CO**



### **Chapter Index**

- 1. BTDA cabinet characteristics
- **1a.KIT Bellcore 4 characteristics**
- **1b.**Test Specifications
- **1c.**Test Results
- 1d.Seismic Zones Zone 4
- 2.BTDA cabinet with KIT Bellcore 4 measures
- 3.General Fixing
- **4.**Top Fixing
- **5.**Middle Fixing
- **6.**Bottom Fixing
- 7. Mounting Plate Top
- **8.**Mounting Plate Middle
- **9.**Mounting Plate Bottom
- **10.**Angle Bracket
- **11.**Enforcing Mounting Plate
- 12.Base
- 13.Base assembly
- 14.Base Fixing on the Ground



### 1.BTDA cabinet characteristics

#### Structure

Profile and rails are made up of a unique closed profile manufactured from 1.5 mm sheet steel,

fully welded and with rounded edges. The frame corners are manufactured with orthogonal joints die-cast of zinc alloys.

#### **Paint finish**

BOSCO standard epoxy polyester powder coating. Structure, door and rear panel RAL 7035 textured finish. Bottom RAL 7035 textured finish.

Other colors on demand availables.

#### **Assembled cabinet**

Supply includes:

- structure
- door manufactured from 2mm sheet steel with stiffening frame, complete with Ø 3mm double bar locking system
- rear panel manufactured from 1.5mm sheet steel
- removable roof manufactured from 1.5mm sheet steel
- bottom with adjustable cable entry manufactured from 1.5mm sheet steel.

#### **Protection degree**

- IP 55 complying with EN50298; EN60529
- type 12 complying with UL508A; UL50
- impact resistance IK10 complying with EN500298; EN50102.



### 1a.KIT Bellcore 4 characteristics

#### Structure reinforcement

On both the two sides are mounted three fixing brakets from 3mm sheet steel:

one on the top, one in the middle and one on the bottom

Special base constructed with two folded sheet (from 3mm sheet steel) welded.

#### **Mounting plate**

Special mounting plate manufactured with 2,5mm thick sheet steel fixed with three fixing brakets 3mm thick sheet steel.

Two additional reinforcements are mounted for weights higher then 100kg.





### **1b.Test Specifications**

#### **Requirements Specification**

#### Earthquake Criteria (Zone 4)

- R 4-68 All equipment shall be constructed to sustain the waveform testing of GR-63-CORE Section 5.4.1 without permanent structural or mechanical damage
- Frame level equipment shall be constructed so that during the waveform testing of GR-63-CORE Section 5.4.1., the maximum single-amplitude deflection at the top of the framework, relative to the base, does not exceed 75 mm.
- **R 4-70** Frame level equipment shall have a natural mechanical frequency greater than 2.0 Hz as determined by the swept sine survey of **GR-63-CORE Section 5.4.1**.
- **O 4-71** Frame level equipment should have a natural mechanical frequency greater than 6.0 Hz as determined by the swept sine survey of **GR-63-CORE Section 5.4.1**.
- **R 4-72** All equipment shall be constructed to meet aplicable functionality requirements immediately before and after each axis of waveform testing of Section 5.4.1. The equipment shall sustain operation without replacement of components, manual rebooting, or human intervention.
- **O 4-73** All equipment shall be constructed to meet aplicable functionality requirements continuously during waveform testing of Section 5.4.1. These functionality criteria shall demonstrate thet the equipment has sustained operation without loss of service during the testing.

#### Framework and Anchor Criteria

- **O4-74** Framework should be of welded construction.
- **R4-75** Framework shall be constructed for base mounting to the floor without auxiliary support or bracing from the building walls or ceilings.
- **04-76** For framework used in earthquake risk zones, the static pull testing procedures of Section 5.4.1.4 should be followed, meeting these objectives:
  - The maximum single amplitude deflection at the top of the framework should not exceed 75 mm (3 in).
  - The top of the framework should return to its original position, within 6 mm (0.24 In) when the load is
  - The framework should sustain no permanent structural damage during static framework testing.
- **R4-77** Concrete expansion anchors used to base mount framework to the floor shall meet the following requirements:
  - Maximum embedment depth of 90 mm (3.5 in)
  - Maximum bolt diameter of 13 mm (0.5 in).
- **04-78** Concrete expansion anchors used to base mount the framework to the floor should be suitable for earthquake (dynamic) applications, as specified by the manufacturer.
- **O4-79** Concrete expansion anchors should use steel construction to minimize creep.



#### **Earthquake Test conditions**

| Environmental parameter    | Test Severity   |                     | Duration | Method                |
|----------------------------|-----------------|---------------------|----------|-----------------------|
| Earthquake<br>time-history | RRS             | see Table nr. 3     | 30 s     | Time-history VERTEQII |
|                            | ZPA*            | 15 m/s <sup>2</sup> |          |                       |
|                            | frequency range | 1 – 50 Hz           |          |                       |
|                            | axes            | 3                   |          |                       |
|                            | damping ratio   | 2 %                 |          |                       |

<sup>\*</sup>Zero Period Acceleration

#### **Earthquake Required Response Spec**trum for Zone 4 according to Telcordia **Technologies GR-63-CORE Section 5.4.1**

| Coordinate Point | Frequency (Hz) | Values for Upper Floor<br>Acceleration (g) |
|------------------|----------------|--|
| 1                | 0.3            | 0.2  |
| 2                | 0.6            | 2.0  |
| 3                | 2.0            | 5.0  |
| 4                | 5.0            | 5.0  |
| 5                | 15.0           | 1.6  |
| 6                | 50.0           | 1.6  |

### **1c.Test Results**

The measured resonance frequencies are:

#### **Results - Resonance Frequencies**

| Axis | Frequency [Hz] |
|------|----------------|
| X    | 9.0            |
| Y    | 6.4            |
| Z    | 47.5           |

#### **Results Earthquake Test**

In detail:

R4-70, O4-71:

R4-68: No structural damages occurred R4-69: The deflection on top was:

> X-axis: 10,6 mm Y-axis: 26,5 mm

Z-axis: no LVDT-measurement was performed The lowest natural gross frequency was 6.4 Hz

The EUT was completed with weight dummys, therefore no function are possible R4-72, O4-73:

R4-74: Framework is not a welded construction. 04-75: Framework is constructed fore base mounting.

04-76: Static pull test not performed, because Framework is synthesized waveform tested. R4-77, O4-78, O4-79: The anchors are unknown and therefore omitted from the test configuration.




### 1d.Seismic Zones – Zona 4

Seismic hazards are those related to ground shaking. Landslides, ground cracks, rockfalls, tsunami - these are all seismic hazards. Generally, though, we think more in terms of damage to our structures and our possessions.


Engineers, seismologists, architects, and planners have carefully evaluated seismic hazards related to building construction. They have devised a system of classifying seismic hazards on the basis of the expected strength of ground shaking and the probability of the shaking actually occurring within a specified time. The results are included in the Uniform Building Code (UBC) seismic provisions.

The UBC seismic provisions contain six seismic zones, ranging from 0 (no chance of severe ground shaking) to 4 (10% chance of severe shaking in a 50-year interval). The shaking is quantified in terms of g-force (familiar to race car drivers and astronauts), the earth's gravitational acceleration. The diagram below is a way of describing seismic zonation.









#### **Construction Standards Required to Meet Code**

| <b>100</b> (100) | 4      | Extreme  |
|------------------|--------|----------|
|                  | 3      | High     |
|                  | 2A, 2B | Moderate |
|                  | 1      | Low      |

#### Seismic test enclosure

Elettromeccanica Bosco doesn't provide his customers with system certified enclosures.

The cabinets are tested for specific configurations under specific conditions and they achieve specific results certified in the documents enclosed.

Any different application of these products could represent a different operating condition and could prejudice the correct functioning of the devices installed.


These different enclosure employments might require additional seismic evaluation to ensure a correct and safe functioning of the equipments installed.

Elettromeccanica Bosco will work closely with the customer to meet the seismic technical requirements and it's also available to assist the customer during testing process.

For further informations please contact: info@elettrobosco.com




### 2.BTDA cabinet with KIT Bellcore 4 measures






### 3.General Fixing







# 3.General Fixing







# 4.Top Fixing






2x: left side + right side










### 5.Middle Fixing







2x: left side + right side















# 6.Bottom Fixing
















# 6.Bottom Fixing









# 7. Mounting Plate Top













# 8. Mounting Plate Middle














# 9. Mounting Plate Bottom









# 10.Angle Bracket




NUT 6MA


SCREW 6MA L15



(2 front + 2 back on top)


(2 front + 2 back on bottom)








mounting on top

mounting on bottom

















### 12.Base



8 pcs SCREW 8MA L16

8 pcs NUT 8MA




8 pcs SCREW 8MA L16

8 pcs NUT 8MA




8 pcs SCREW 6MA L16

8 pcs NUT 6MA











### 12.Base


### side base and cover




#### front reinforced cover

























# 14.Base - Fixing on the Ground


#### axonometric view from bottom







**Tightening Strength: 100Nm** 




front





# 14.Base - Fixing on the Ground



# 11.Base - Fixing on the Ground two coupled cabinet

